


OSM/IN DECISION

Standard: EN 50075:1990	Sub clause: General	Sheet N°: OSM/IN 202A
Subject: Coil incorporated in 2.5 A Europlugs	Key words: Coil	Meeting N°: 12 - 16 - 17 - 22 - 23 Item: 9.4 - 6.1 - 3.4.1 - 3.4.4 - 4.4.2
Question:	Are any additional tests needed for 2,5 A plugs fitted with a coil for electromagnetic interference suppression?	
		
Decision:	The following tests have to be done: Use applicable Clauses in EN 50065-4-7. For test currents refer to Table 20 of IEC 60884-1.	
Explanatory notes:	This Decision Sheet replaces decision sheet OSM/IN 202.	