



COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60730-1:2000	Sub clause: 2.10.1	Sheet no. OSM/IN 137 Page 1(1)
Subject: A cable or cord to an external SELV sensor	Key words: Cord External SELV device	Meeting no. 10 Item 6.14
Question:	It is a cable or cord of an external SELV device (sensor) considered to be an external conductor as defined in clause 2.10.1?	
Decision:	A cable or cord of an external SELV device (sensor) is not considered to be an external conductor as defined in clause 2.10.1. It is not necessary for such cables or cords, whether detachable or not, to comply with clause 11.8.1	
Explanatory notes:	<p>This interpretation is taken from CENELEC TC72(Secretariat) 72K/INF, interpretation Nr. 09/01/19/12 according to the decision taken in the seventh OSM/IN Meeting In Copenhagen(1997). See minutes of mentioned Meeting document OSM/IN(ES/AENOR)20/97 Rev. 1, item 4 (Matters pending from Offenbach Meeting (1996), item 6.5).</p> <p>??Date: 2003-05-01</p>	