



COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60730-1:2000	Sub clause: N.1	Sheet no. OSM/IN 138
		Page 1(1)
Subject: Conductive pollution described in clause N.1	Key words: Cord External SELV device	Meeting no. 10 Item 6.14
Question:	What it is the degree of pollution described in clause N.1 note 2 of Annex N?	
Decision:	<p>Conductive pollution described in clause N.1 note 2 should be considered as pollution degree 2 unless the area is affected by other pollution, in which case the pollution degree corresponding to the other pollution applies.</p> <p>If this interpretation is not accepted, then controls which previously passed according to the requirements for the operational insulation of the previous edition may not meet the requirements for pollution degree 3 of this edition.</p>	
Explanatory notes:	<p>This interpretation is taken from CENELEC TC72(Secretariat) 72K/INF, interpretation Nr. 08/01/19/11.1 according to the decision taken in the seventh OSM/IN Meeting In Copenhagen(1997). See minutes of mentioned Meeting document OSM/IN(ES/AENOR)20/97 Rev. 1, item 4 (Matters pending from Offenbach Meeting (1996), item 6.5).</p>	