



COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60730-2-9:2002	Sub clause: 17.7.3	Sheet no. OSM/IN 139 Page 1(1)
Subject: Control declared as sensing element	Key words: Control device sensing element	Meeting no. 10 Item 6.14
<p>Question: Where the whole control is declared as a sensing element, is applicable clause 17.7.3 ?</p> <p>Decision: Clause 17.7.3. Add at the end of the subclause: “Where the whole control is declared as a sensing element, Tmin is not applicable and this subclause does not apply.”</p> <p>Explanatory notes: This interpretation is taken from CENELEC TC72(Secretariat) 72K/INF, interpretation Nr. 01/2-9/18/11.1 according to the decision taken in the seventh OSM/IN Meeting In Copenhagen(1997). See minutes of mentioned Meeting document OSM/IN(ES/AENOR)20/97 Rev. 1, item 4 (Matters pending from Offenbach Meeting (1996), item 6.5).</p>		