


OSM/IN DECISION

Standard: EN 60670-1:2005	Sub clause: 12.1.2.4	Sheet N°: OSM/IN 233
Subject: Definition of “reverse tapers”	Key words: Reverse tapers	Meeting N°: 18 Item: 9.2

Question: The term “reverse tapers” is not clear.

Decision: A representative drawing, in addition to Figure 17, regarding the application of the gauge of Figure 16 is given below.



Cover plate with reverse taper

gauge of Figure 16

In this case the test according to sub-clause 12.1.2.4 failed as the gauge enters more than 1 mm from the upper part of the reverse taper.

Explanatory notes: -