

OSM/IN DECISION

Standard: EN 60669-1:1999 + A1:2002	Sub clause: 13.2	Sheet N°: OSM/IN 239
Subject: Correct positioning of conductors	Key words: Correct positioning	Meeting N°: 18 Item: 5.1
Question:	Whether or not a correct positioning of the conductor can only be ensured if the screw terminals can be actuated (tightened) after the switch is mounted into the box.	
Decision:	The correct positioning of the conductors does not include the tightening of the screw terminal after mounting of the switch base of the accessory on the wall or in the box. The standard in fact includes constructions with terminals placed on the front and constructions with terminals placed on the rear part of the accessory.	
Explanatory notes:	Decision transferred from OSM/IN 040, concerning EN 60669-1:1995, based on the same subject. Decision originally agreed by WG4/SC 23B of IEC.	