

OSM/IN DECISION

Standard: EN 60669-1:1999 + A1:2002	Sub clause: 20.4.1	Sheet N°: OSM/IN 241
Subject: Verification of non-removal of covers, cover plates or actuating members	Key words: Non-removal	Meeting N°: 18 Item: 5.1
Question:	There is some confusion over the way to apply the forces prescribed by the standard.	
Decision:	The test shall be carried out by applying the forces in a direction perpendicular to the mounting surface and in such a way they do not cause a torque.	
Explanatory notes:	Decision transferred from OSM/IN 042, concerning EN 60669-1:1995, based on the same subject. Interpretation originally made by WG4/SC 23B of IEC (see sketches in the next page).	

OSM/IN DECISION

Standard: EN 60669-1:1999 + A1:2002	Sub clause: 20.4.1	Sheet N°: OSM/IN 241
Subject: Verification of non-removal of covers, cover plates or actuating members	Key words: Non-removal	Meeting N°: 18 Item: 5.1

