

OSM/IN DECISION

| | | |
|--|--|--|
| Standard: EN 60730-1:2000 + A12:2003 + A1:2004 + A13:2004 + A14:2005 + A15:2007 + A16:2007 + A2:2008 | Sub clause: 14 | Sheet N°: OSM/IN 251 |
| Subject: Behaviour of a protection device during heating test | Key words: - heating | Meeting N°: 19 (2009) Item: 6.6 |
| Question: | Is it allowed that during the heating test a protection device operates? | |
| Decision: | No. This is in line with the general approach existing in other standards like EN 61058-1, EN 60669-2-1 and EN 60335-1 where during the heating test any protection device shall not operate. | |
| Explanatory notes: | - | |