

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
IEC 60598-1 (6 th & 7 th edition)	4.14	DSH 0862	2014
Category:			
LITE			
Subject:	Key words:	Developed by	
Suspension devices for recessed luminaire	<ul style="list-style-type: none"> - Fixed luminaires - Fixing devices - Test A 	ETF5-OSM/LUM	
Question			
<p>In our opinion a recessed luminaire is considered as a suspended luminaire for this sub clause. In such case, the fixing devices shall be tested according to test A (four times the weight of the luminaire). Do other colleagues agree with this interpretation?</p>			
Decision			
<p>It applies to all fixed luminaires.</p>			
Explanatory notes			
<p>In the 8th Edition of IEC 60598-1, the test A has been modified and clearly states that the test shall be done also for the external parts attached to the luminaire.</p>			