

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
IEC 60598-1/2008	5.2.2	DSH 0878	2014
<b>Category:</b>			
LITE			
<b>Subject:</b>	<b>Key words:</b>	<b>Developed by</b>	
Insulation required on a cable (SELV operating)	<ul style="list-style-type: none"> <li>- Basic insulated parts</li> <li>- SELV plug-in</li> <li>- Transformer</li> </ul>	ETF5-OSM/LUM	
<b>Question</b>			
<p>What are the insulation requirements for a cable longer than 80 mm, operating at SELV, intended to supply a luminaire through a plug-in transformer?</p>			
<b>Decision</b>			
<p>Basic insulation is acceptable for parts operating at SELV.</p>			
<b>Explanatory notes</b>			
<p>The matter is covered by IEC 60598-1/2014.</p>			