

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	0.4.2	DSH 0818A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Instruction manual of a floodlight	- Mounting instructions - Unfavourable - Instructions manual	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>The instruction manual of a floodlight contains limitations for use (e.g. mounting angle of 45° max).</p> <ol style="list-style-type: none"> 1) How is the luminaire mounted during the endurance test and thermal test (§§ 12.3 / 12.4)? 2) How is the luminaire mounted during the IP test (§ 9)? 			
Decision			
<ol style="list-style-type: none"> 1) The mounting instructions have to be followed. 2) The most unfavourable position according to the manufacturer instructions manual. 			
Explanatory notes			
