

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	3.2.8	DSH 0835A	2019
<b>Category:</b>			
LITE			
Subject:	Key words:	Developed by	Approved at
Lamp type information marking	<ul style="list-style-type: none"> <li>- Manufacturer</li> <li>- Marking plate</li> <li>- Instructions</li> </ul>	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
<b>Question</b>			
<p>In what way should the lamp-type information be rated when MT-400-type lamps are used (when ballast manufacturer has specified the ballast to be used only with certain manufacturer's MT-400-type lamp)? Rating MT-400 does not give the necessary information.</p>			
<b>Decision</b>			
<p>Marking plate should have manufacturer specific rating for example HPI-T (Philips) and installation instructions should specify the appropriate(s) lamp(s) with more details (manufacturer etc.).</p>			
<b>Explanatory notes</b>			
---			