


OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	4.14.1	DSH 0864A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Clip-mounted luminaire: pulling test	<ul style="list-style-type: none"> - Clip-Mounted luminaire - No movement - Unfavourable direction 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting

Question

Test for clip-mounted luminaires, pulling in some directions, (direction Z, see the figure). It is practically impossible to have a clip which does not start to move on glass, even though the movement could not degrade the quality of the fixing. Is there any movement permitted?



Decision

Standard has to be followed. The most unfavourable direction must be tried and no movement is allowed.

Explanatory notes
