

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60598-1:2015/A1:2018	5.3.5	DSH 2091A	2019
Category			
LITE			
Subject	Keywords	Developed by	Approved at
Use of H03VH7-H 1x0.75mm <sup>2</sup> cables for suspended part of pendant luminaire	<ul style="list-style-type: none"> <li>- Internal wiring</li> <li>- External wiring</li> <li>- Suspended part</li> </ul>	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Is H03VH7-H cable rated 1x0.75 mm<sup>2</sup> (longer than 80mm) allowed to be used for the suspended part of pendant luminaires?</p>			
Decision			
<p>Yes.</p>			
Explanatory notes			
<p>---</p>			