

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	8.2.3	DSH 0900A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Metal fixing devices for components	<ul style="list-style-type: none"> - Live parts - Reinforced insulation - Fixing device 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>1) Metal fixing screws of connecting device accessible during the lamp replacement and provided with reinforced insulation against live parts.</p> <p>2) Metal fixing device of plastic capacitor, connected to accessible metal parts of luminaire and provided with reinforced insulation against live parts.</p> <p>Are the above mentioned constructions acceptable?</p>			
Decision			
<p>Both constructions are acceptable, if all tests for reinforced insulation are fulfilled.</p>			
Explanatory notes			
<p>--</p>			