

		LOVAG DECISION SHEET (LDS)		N°[LDS186]
				Pag. 1 of 1
References	Standard(s) (incl. year)	[IEC 61439-1: 2011]		Subclause(s): 10.9.1
	Subject	[Dielectric properties	Submitted by: TECNALIA	Date: [31/05/2018]
Question	<p>For this test, all the electrical equipment of the ASSEMBLY shall be connected, except those items of apparatus which, according to the relevant specifications, are designed for a lower test voltage.</p> <p>When and who decides an apparatus to be disconnected?</p>			
	<p>The use of apparatus designed for lower test voltages should be a matter of agreement between manufacturer and user.</p>			
Decision	<p>These apparatuses must be indicated by the applicant to the laboratory and certification body. Disconnected apparatus will be reported in the test report.</p>			
	Date: [19/06/2018]	Prepared by: [Tecnalia]	Approved by: [LOVAG Technical Committee]	