

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	7.2.1	DSH 0892A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Earthing in luminaire system	<ul style="list-style-type: none"> - Metal body - Each luminaire - Fixed installation 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>In a luminaire system:</p> <p>a) Can the metal body provide earth continuity instead of copper conductor?</p> <p>b) Can the earth continuity be connected in series (feed through) as part of the fixed installation?</p>			
Decision			
<p>a) Not acceptable.</p> <p>b) Not acceptable, each luminaire must be directly earthed.</p>			
Explanatory notes			
