

COLLECTION OF CIG-OSM/IN DECISIONS

<p>Standard: EN 50086-2:1995 EN 50086-2-2:1995 EN50086-2-3:1995 EN 50086-2-4:1994</p>	<p>Sub clause: General</p>	<p>Sheet no. OSM/IN 021</p> <p>Page 1(1)</p>
<p>Subject: Certification Procedure for conduits and conduit fittings</p>	<p>Key words: Certification procedure</p>	<p>Meeting no. 6 7 8</p> <p>Item 6.26 6.21 4 (Copenhagen 6.21)</p>
<p>Question: Different Certification Procedure followed by different Certification Bodies?</p> <p>Decision: To accept the philosophy for which the certification for conduits or conduit fittings. Is possible according to EN 50086-1 if the dimensions of products, such as Outside diameters or threads, are in conformity with EN 60423 (this is mainly. Possible in the field of application of EN 50086-2-1 and EN 50086-2-2). In fact. The conformity with EN 60423 of the conduits and fittings can assure the correct Interchangeability also between products of different manufacturers.</p> <p>All other products, such as flexible conduits (EN50086-2-3) or conduits buried underground (EN 50086-2-4) which require to be mounted with their special fittings to function properly, should be considered as part of “conduit system”.</p> <p>Explanatory notes:</p>		

