

COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60 730-2-4:1993	Sub clause: 20.101	Sheet no. OSM/IN 066 Page 1(1)
Subject: Creepage distances and clearances across micro-interruption	Key words: Creepage distances and clearances	Meeting no. 6 7 Item 6.5 4 (Matters pending from Offenbach meeting (1996) 6.5)
Question:	EN 60 730-1 in Table 20.1 says: “Across micro-interruption: there are no requirements other than between terminals and terminations. Between terminals and terminations the requirements are as for operational insulation.”	
Decision:	Clause 20.101 The interpretation of the exclusion is that it also applies to terminals and terminations and therefore it is to be interpreted that added to the exclusion of 20.101 are the words ‘This exemption includes terminals and terminations’	
Explanatory notes:	1) This interpretation has been consulted by OSM/IN to CLC/TC 72 according to the decision taken in OSM/IN Offenbach Meeting and taken from the document CLC/TC 72 (Secretariat) 72 A interpretation 01 /2-4/11/17.4 according to the decision taken in OSM/IN Copenhagen Meeting (1997). See Interpretation Sheet OSM/IN 065 .	