

COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60730-1:1995	Sub clause: 17.3.1	Sheet no. OSM/IN 083 Page 1(1)
Subject: Additional tests for automatic electrical controls with Tmax below 0 °C	Key words: automatic electrical controls	Meeting no. 10 Item 6.14
<p>Question: If T_{min} is less than 0 °C, additional tests shall be carried out with the switch head maintained between T_{min} and $(T_{min}-5)$ °C. What additional tests are required?</p> <p>Decision:</p> <ul style="list-style-type: none"> - Type 1 controls – clauses 16 and 17 - Type 2 controls – clauses 15, 16 and 17 3 x Additional samples required. <p>Explanatory notes: See CLC/TC 72 (SEC) 72E. Interpretation agreed by CLC/TC72.</p>		