

## COLLECTION OF CIG-OSM/IN DECISIONS

<b>Standard:</b> EN 60730-1:1995 & EN 60730-1:1995 /A17:2000	<b>Sub clause:</b> H23	<b>Sheet no.</b> OSM/IN 086  <b>Page 1(1)</b>
<b>Subject:</b> Clarification of the Standard text	<b>Key words:</b> Clarification	<b>Meeting no.</b> 7  <b>Item</b> 4(Matters pending from Offenbach Meeting 6.5)
<p><b>Question:</b> Meaning of the text: “load terminals and AC mains”</p> <p><b>Decision:</b> For the purposes of using Table H.23, “load terminals and AC mains”, are understood to be “load terminals which are in connection with AC mains”</p> <p><b>Explanatory notes:</b> 1) This interpretation is taken from CENELEC TC72 (Secretariat) 72D interpretation Nr 04/01/14/09 according to the decision taken in the seventh OSM/IN Meeting in Copenhagen (1997). See minutes of mentioned Meeting document OSM/IN (ES/AENOR) 20/97 Rev. 1 item 4 (Matters pending from Offenbach Meeting (1996) item 6.5)</p> <p style="text-align: center;">Interpretation agreed by CLC/TC72</p>		