

COLLECTION OF CIG-OSM/IN DECISIONS

| | | |
|---|---|---|
| Standard: EN 60947-3:1999 | Sub clause: 8.2.5.2 | Sheet no. OSM/IN 094 Page 1(1) |
| Subject: Test forces for actuators | Key words: Test forces | Meeting no. 10 Item 6.21 |
| Question: | It is not clear in which case the actuator is two-finger operated and when one-hand operated. The choice is very essential because maximum test force can be either 200 N or 400 N. | |
| Decision: | One-hand operated actuator could be such that the whole hand fits around the handle of the actuator. Otherwise the actuator is two-finger operated | |
| Explanatory notes: | - | |