



## CIG-OSM/IN DECISION

<b>Standard:</b> EN 61008-1:1994	<b>Sub clause:</b> Amendment 2	<b>Sheet N°:</b> OSM/IN 102B <b>Page:</b> 1(1)
<b>Subject:</b> EMC Testing for RCCB's	<b>Key words:</b> - EMC - RCCB's	<b>Meeting N°:</b> 6 - 16 - 17 <b>Item:</b> 6.24 - 5.1 - 3.4.1
<p><b>Question:</b> Whether or not to include Amendment 2 on NTRs for RCCB's.</p> <p><b>Decision:</b> To include in NTRs EMC testing according to EN 61008-1:1994/A2:1995 as from 2000-07-01 (dow). No follow-up testing shall be performed except in cases of changes in RCCB's certified that can affect EMC compliance. The Test Report shall include the complete circuit diagram as well as complete list of components incorporated in the detection circuitry of RCCB's.</p> <p><b>Explanatory notes:</b> See OSM/IN 105B</p>		