



CIG-OSM/IN DECISION

Standard: EN 61009-1:1994	Sub Amendment clause: 1	Sheet N°: OSM/IN 105B Page 1(1)
Subject: EMC Testing for RCBO's	Key words: - EMC - RCBO's	Meeting N°: 8 - 16 - 17 Item: 6.29 - 5.1 - 3.4.1
Question:	Whether or not to include Amendment 1 on NTRs for RCBO's.	
Decision:	To include in NTRs EMC testing according to EN 61009-1:1994/A1:1995 as from 2000-07-01 (dow). No follow-up testing shall be performed exception cases of changes in RCBO's certified than can affect EMC compliance. The Test Report shall include the complete circuit diagram as well as complete list of components incorporated in the detection circuitry of RCBO's.	
Explanatory notes:	See OSM/IN 102B	