

## COLLECTION OF CIG-OSM/IN DECISIONS

<b>Standard:</b> EN 61009-1:1994 and EN 61009-2-1:1994	<b>Sub clause:</b> G.4.1 (Annex G)	<b>Sheet no.</b> OSM/IN 107  <b>Page 1(1)</b>
<b>Subject:</b> Constructional requirements	<b>Key words:</b> Constructi onal	<b>Meeting no.</b> 5  <b>Item</b> 6.15
<b>Question:</b> Definition of a “proper construction” in the meaning of G.4.1.		
<b>Decision:</b> A proper construction in the meaning of that sub-clause is that: <ul style="list-style-type: none"> <li>- provisions are taken to assemble the unit once</li> <li>- the fixing means are captive</li> <li>- if dissociated unit shows visible damages.</li> </ul> <p style="text-align: center;">In cases one way screws are used it shall be checked that they cannot be removed. Furthermore the unit shall not be dissociated.</p>		
<b>Explanatory notes:</b> -		