

## COLLECTION OF CIG-OSM/IN DECISIONS

<b>Standard:</b> EN 61009-1:1994 and EN 61009-2-1 :1994	<b>Sub clause:</b> G.4.4. d) (Annex G)	<b>Sheet no.</b> OSM/IN 111  <b>Page 1(1)</b>
<b>Subject:</b> Uniform interpretation of sub-clause G.4.4.d)	<b>Key words:</b> Uniform interpretat ion	<b>Meeting no.</b> 5  <b>Item</b> 6.15
<p><b>Question:</b> Doubts of interpretation.</p> <p><b>Decision:</b> The uniform application of that sub-clause is to avoid assembly with CB having uninterrupted neutral pole, 1P → 1P+N (2P), 3P → 3P+N (4P).</p> <p><b>Explanatory notes:</b> -</p>		