

COLLECTION OF CIG-OSM/IN DECISIONS

Standard: EN 60730-2-14:1997	Sub clause: 2.7.5	Sheet no. OSM/IN 140
		Page 1(1)
Subject: Class II symbol is applicable	Key words: Class II symbol	Meeting no. 10 Item 6.14
Question:	<p>Removal of the last part of the sentence, '<i>or reliance upon installation conditions</i>' was requested.</p> <p>Addition of the following new note to sub clause 2.7.5 of EN 60730-2-14 as follows:</p> <p style="padding-left: 40px;"><i>“Control in which protection against electrical shock does not rely on basic insulation only, but in which additional protective precautions, such as double insulation or reinforced insulation, are provided, there being no provision for protective earthing. Such a control may be one of the following types:</i></p> <p style="padding-left: 40px;"><i>Note 1. Class II controls may have parts operating at safety extra-low voltage.</i></p> <p style="padding-left: 40px;"><i>Note 2. The connection to the fixed installation - with or without a plug - is not considered to be a part of the control'</i></p>	
Decision:	<p><i>'Actuators of class II construction provided with a cord for connection to the fixed wiring which does not have a plug fitted may carry the symbol for class II construction.'</i></p>	
Explanatory notes:	<p>This interpretation is taken from CENELEC TC72(Secretariat) 72K/INF, interpretation Nr. 01/2-14/18/12 according to the decision taken in the seventh OSM/IN Meeting In Copenhagen(1997). See minutes of mentioned Meeting document OSM/IN(ES/AENOR)20/97 Rev. 1, item 4 (Matters pending from Offenbach Meeting (1996), item 6.5).</p>	